

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20173605, Public Works Infrastructure Permit - Commercial
Village at View High - Off-Site Sanitary Sewer
Address: 325 NW VIEW HIGH DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Sanitary Sewer - Invert	Steve Robbins	Partial	Friday, March 23, 2018

Informational

- 1 Today the contractors poured all the inverts for the 15 MH's. I still have a few more to look at but they appear to be good. MH A-0 was holding some water but I talked with Kent and Gene and they said it is because they had to come in below the flow line. They did it according to the plans because it is all that could be done. Steve Robbins 03/23/2018 3:52 PM

Comments: