



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

| | | | |
|------------------|--|------------|-----------------------|
| Permit No: | PRCOM20171355 | Date: | March 26, 2018 |
| Project Title: | CONTROL SERVICE COMPANY | Applicant: | |
| Location: | 3621 NE AKIN DR, LEES SUMMIT, MO 64064 | | |
| Type of Work: | | | ARCHWAY SYSTEMS LLC |
| Occupancy Group: | | | 809 NE ANDERSON LN |
| Description: | TENANT FINISH FOR OFFICE WITH SOME STORAGE | | LEES SUMMIT, MO 64064 |
| | | Primary: | (816) 709-3358 |

**due to timing both this TF permit and the shell were approved simultaneously. This permit will be voided and all fees and any relevant plan review conditions will be moved to full building permit PRCOM20170784
Construction Type: Not Applicable
Map Page: 175M

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test. Acceptance testing of the system is required prior to the final occupancy inspection. contact the fire department to schedule testing. (816)969-1300.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.