
PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRRES20173776, Building Permit - Residential

Address: 1713 NE PARKWOOD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Sidewalk Inspection	Jeremy Young	Passed	Wednesday, March 28, 2018

Informational

- 1 Jeremy Young 03/28/2018 9:36 AM Contractor has poured concrete. There is at least 6" of rock in the ROW. The cross slope is between 1.1-1.9% through the sidewalk.

Comments:
