

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161758, Building Permit - Commercial

Address: 789 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Wednesday, March 28, 2018

Partial Correction

1	Misc	OK TO COVER WHEN READY TRENCHED SITE LIGHTING CONDUIT AT: BETWEEN POINTS #1 - #3; NW FROM #4; 1" PVC FROM SOUTH FRONT OF CLUBHOUSE TO NORTH REAR OF BLDG #1 DETACHED GARAGE; 3/4" PVC AT BLDG #1 CARPORT & DETACHED GARAGE; 3/4" PVC SOUTH SIDE GROUND LIGHTING; IN ISLANDS E OF BLDG 5 AND BLDG 4 + BEHIND DETACHED GARAGE @ BLDG 4; [ALONG W SIDE OF BLDG 4; ALONG E SIDE OF BLDG 3; BETWEEN N & S DETACHED GARAGES AT BLDG 1; 3/4" CONDUIT FROM E EDGE OF BLDG 2 PARKING LOT E TO SIDEWALK, THEN BORED S TO L.P. SCREWED-IN BASE; CONDUIT N/NE OF BLDG 6 + AT ISLAND N OF BLDG 6; BETWEEN DETACHED GARAGES AT BLDG #6; FROM N END OF N DETACHED GARAGE W OF BLDG #7 TO 150' NE; [IN ISLAND W OF BLDG 3 FROM SEWER M.H. NORTH TO N END OF CARPORT; REPLACEMENT/REPAIR OF DAMAGED CONDUIT E OF BLDG 3 FROM Q-BOX TO ~60' SOUTH;
---	------	---

Comments: