

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20180366, Building Permit - Commercial

Address: 400 SW LONGVIEW BLVD, Unit:125, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Mark Harding	Passed	Friday, March 30, 2018
In-wall Inspection	Mark Harding	Passed	Friday, March 30, 2018

Comments: