

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRRES20173335, Building Permit - Residential

Address: 1709 NE PARKWOOD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Jeremy Young	Partial	Friday, March 30, 2018

Informational

1 Jeremy Young 03/30/2018 1:42 PM John DiMauro and I were on site. The contractor had sufficient rock bedding, at least 4" of rock. There is a sidewalk through the driveway. I reminded the contractor to keep below 2% through the ADA for compliance. They will add the expansion joint and pour.

Driveway Inspection	John DiMauro	Partial	Friday, March 30, 2018
---------------------	--------------	---------	------------------------

Comments: