

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20173335, Building Permit - Residential

Address: 1709 NE PARKWOOD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Residential	John Borns	See comments	Friday, March 30, 2018
Driveway Inspection	Jeremy Young	Partial	Friday, March 30, 2018
Driveway Inspection	John DiMauro	Partial	Friday, March 30, 2018

Comments: THREE PIER HOLES FOUND DUG 36"+ DEEP x 14"-16" DIAMETER. NO PRINTS FOUND ON SITE TO INDICATE DESIGN DIMENSIONS. IF APPROVED DRAWINGS SHOW DESIGN DIMENSIONS CORRESPOND WITH HOLES AS DUG OK TO POUR WHEN READY.