

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20173935, Building Permit - Commercial

Address: 910 NW BLUE PKWY, Unit:A, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	John Borns	Passed	Monday, April 02, 2018
Gas Service Inspection - Commercial	John Borns	Passed	Monday, April 02, 2018

Comments: ADDRESS IDENTIFICATION OF GAS SERVICE ENTRY: WHERE TWO OR MORE SERVICES ARE GROUPED LOOSE-HANG ADDRESS-STAMPED MEDALLION ON LOAD SIDE PIPE.