

Temporary Certificate of Occupancy

Permit #: PRCOM20161180
Address: 501 NW SHAMROCK AVE, LEES SUMMIT, MO 64081521 NW SHAMROCK AVE, LEES SUMMIT, MO 64081
Inspected On: Tuesday, April 03, 2018
Inspected By: John Borns
Expiration Date: 4/26/2018 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Temporary C of O	Tuesday, April 03, 2018

Corrective Action Required:

1	Misc	CODES ISSUES AT BUILDING EXTERIOR & SITE: - SEAL OPENINGS/PENETRATIONS @ EXTERIOR WALLS - CUT SANITARY CLEANOUT RISERS TO GRADE; CAP - UNFINISHED SIDING & TRIM AT EXTERIOR WALLS - SPLASH BLOCKS OR EQUIVALENT EROSION CONTROL REQUIRED AT BOTTOMS OF DOWNSPOUTS - REPAIR/REPLACE DAMAGED SHROUDS AT BASES OF LIGHT POLES; CLOSE WIRING ACCESS OPENINGS
---	------	--

Corrective Action Required:

2	Miscellaneous Correction	OTHER DEPARTMENTS DIVISIONS TO APPROVE: LSFD CIVIL PLANNING
---	--------------------------	--

