

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20173421, Building Permit - Residential

Address: 612 NW OLIVE ST, Unit:A, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	John Borns	Passed	Wednesday, April 04, 2018

Comments: OK TO COVER WHEN READY CEILING AT 1ST FLOOR + CEILING AND WALLS AT UPPER LEVEL. CALL TO REQUEST FINAL INSPECTION WHEN READY. FINAL INSPECTION WILL INCLUDE, BUT NOT BE LIMITED TO, COMPLIANT STAIR, GUARDS, AND HANDRAIL. ALL ELECTRICAL RECEPTACLES IN GARAGES MUST BE GFCI PROTECTED.