

**PUBLIC WORKS ENGINEERING DIVISION**

## **Inspection Summary**

---

Permit #: PRSITE20180252, Development - Site

TAILOR MADE LANDING

Address: 1600 SE HAMBLER RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection Item:

<b>Inspection:</b>	<b>Inspector:</b>	<b>Outcome:</b>	<b>Date:</b>
DE-Fire Line Construction Inspection Informational	John DiMauro	Partial	Thursday, April 05, 2018
1	John DiMauro 04/05/2018 9:53 AM		

A crew is on site working on the fire line install. The backflow vault is set and the crew is installing pipe for the line. There appears to be sufficient rock bedding at this time.

**Comments:**

---