

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20180434, Building Permit - Commercial

Address: 2751 NE DOUGLAS ST, Unit:X, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Khanh Nguyen	Partial	Thursday, April 05, 2018

Partial Correction

1	Miscellaneous Correction	-UFER GROUNDING CONNECTION (CAD WELD TO REBAR) CONFIRMED
---	--------------------------	---

Footing Inspection - Commercial	Khanh Nguyen	Partial	Thursday, April 05, 2018
--	--------------	---------	--------------------------

Partial Correction

1	Miscellaneous Correction	EXTERIOR GRADE BEAM&COLUMN PIERS OK: -FROM FIRST COLUMN AT SE CORNER COUNTER-CLOCKWISE TO 3RD COLUMN FROM NW CORNER
---	--------------------------	---

Comments: