
PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRRES20173335, Building Permit - Residential

Address: 1709 NE PARKWOOD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Jeremy Young	Passed	Friday, April 06, 2018

Informational

- 1 Jeremy Young 04/06/2018 9:52 AM Driveway has been poured. There is at least 6" of concrete in the ROW. The cross slope is between .04-1.9%. The expansion joint is present.

Comments:
