# **Development Services Department**

220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

## **Inspection Summary**

Permit #:PRRES20173808, Building Permit - Residential Address: 4716 NE POCONO CIR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection - Khanh Nguyen Failed Tuesday, April 10, 2018

Residential

#### Corrective Action Required

Miscellaneous Correction FRAMING:

- -Nail all exterior CSPF wall siding per code
- \*\*look at the brace wall nailing detail. Nail to stud and header @
- 3" oc just like the garage portal brace wall
- -Frame CSPF walls per A/4 plan detail (greatroom and dining)
- -Expose rear patio framing support
- -Toe nail joists to wall top plates
- \*\*3-8d toe nails
- -Engineer to address non-continuous 2x6 studs at rear great-room wall
- -Cut joist below master toilet
- \*\*have your engineer look at this and address fix
- -Provide solidblock support underneath foyer and mud Ivl beams point loads and underneath dining I beam
- -Brace interior walls per plan

#### **ELECTRICAL:**

- -Provide wall receptacle spacing per code near basement wet bar
- \*\*at any point along the wall-except the hall way-there shall be a receptacle within six ft
- -Install a receptacle in unfinished space under stoop

### \*\*DO NOT INSULATE

**Electrical Service** Khanh Nguyen Failed Tuesday, April 10, 2018 **Inspection - Residential** 

**Corrective Action Required** 

1 Miscellaneous Correction -Install a listed rebar grounding clamp. The currently install one is for copper rod connection. Avoid copper-iron contact

### **Comments:**