Development Services Department

220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20170806, Building Permit - Residential Address: 1836 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Occupancy Inspection - Mark Harding Failed Tuesday, April 10, 2018

Codes Residential

Corrective Action Required

R313 SMOKE ALARMS - CONNECT BSMT BATH VENT. BACK UNFINIHSED AREA.

-LABEL SMOKES.

- LAWN SPRINKLER PERMIT.

-HAMMER ARESTOR

-BSMT BEDROOM HAS NO EGRESS CANNOT BE USED AS

BEDROOM WITH A CLOTHES CLOSET.

-ROCK UNDER BSMT STAIRS

-SELF CLOSING GARAGAE DOOR HINGE

Comments: