Development Services Department

220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20170810, Building Permit - Residential Address: 1832 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Occupancy Inspection - Mark Harding Failed Tuesday, April 10, 2018

Codes Residential

Corrective Action Required

1 R311 MEANS OF EGRESS - SUMP PUMP DISCHARGE

- LAWN SPRINKLER PERMIT

-NO OUTLETS MSTR VANITY

-MSTR TUB ACCESS

-SMOKE HANGING FROM CEILING NE BED.

-NO WALL OUTLET, WALL WITH THERMOSTAT 1ST FLOOR

-LABEL SMOKES AT PANEL.

-CUT DRAIN PIPE AND CLEAN OUT WINDOW WELL.

-NO ANTI SIPHON BSMT HOSE BIB

-SELF CLOSING GARAGE DOOR HINGE

-NO HANDRAIL IN GARAGAE

- HOOD NOT WIRED OR INSTALLED

-2ND LOCKING DEVISE FOR SLIDING DOOR

- NO REAR STEPS.

Comments: