

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20173935, Building Permit - Commercial

Address: 910 NW BLUE PKWY, Unit:A, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mike Copeland	Failed	Wednesday, April 11, 2018

Corrective Action Required

3	Miscellaneous Correction	ALL DEBRIS AND UNUSED MATERIAL TO BE REMOVED FROM ROOFTOP. ALL ROOFTOP MECHANICAL EQUIPMENT TO BE LABELED AND DESIGNATIONS REFLECTED AT ELECTRICAL PANEL.
---	--------------------------	---

Comments: