

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20173802, Public Works Infrastructure Permit - Commercial

Residences at Echelon

Address: 3500 SW HOLLYWOOD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Water - Material Verification Informational	Matt Munger	Partial	Thursday, April 12, 2018
1	Matt Munger 04/12/2018 9:32 AM I looked over the C900 water pipe that was delivered on the site (approx. 1260ft). I did not see any defects in the pipe. The pipe was stamped C900 DR 18 PC 235 with a manufactured date of November 17'.		

Comments: