

---

**PUBLIC WORKS ENGINEERING DIVISION**

## **Inspection Summary**

---

Permit #: PRPWFR20171420,  
CREEKSIDE AT RAINTREE

Address:

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection Item:

<b>Inspection:</b>	<b>Inspector:</b>	<b>Outcome:</b>	<b>Date:</b>
DEI-Curb - Proof Roll	Brice Lawson	Passed	Thursday, April 12, 2018

Informational

1 Brice Lawson 04/12/2018 2:18 PM

A proof roll was performed on the base rock where the curb will be installed. There did not appear to be any rutting, pumping or deflection of the base rock during the proof roll.

**Comments:**

---