

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20180430, Building Permit - Commercial

Address: 2751 NE DOUGLAS ST, Unit:W, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	Khanh Nguyen	Partial	Thursday, April 12, 2018

Partial Correction

1	Misc	-INTERIOR COLUMN PIERS OK -EXTERIOR GB OK, EXCEPT 20 FT SECTION AT SE CORNER
---	------	---

<b>Underground Electrical Inspection - Commercial</b>	Khanh Nguyen	Partial	Thursday, April 12, 2018
---	--------------	---------	--------------------------

Partial Correction

1	Misc	-UFER GROUNDING CONNECTION INSPECTED-OK
---	------	---

**Comments:**