

**PUBLIC WORKS ENGINEERING DIVISION**

## Inspection Summary

Permit #: PRPWFC20173802, Public Works Infrastructure Permit - Commercial  
Residences at Echelon  
Address: 3500 SW HOLLYWOOD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

**Inspection Item:**

<b>Inspection:</b>	<b>Inspector:</b>	<b>Outcome:</b>	<b>Date:</b>
DEI-Water - Material Verification Informational	Matt Munger	Partial	Thursday, April 12, 2018
1	Matt Munger 04/12/2018 9:32 AM I looked over the C900 water pipe that was delivered on the site (approx. 1260ft). I did not see any defects in the pipe. The pipe was stamped C900 DR 18 PC 235 with a manufactured date of November 17'.		
DEI-Water - Material Verification Informational	Matt Munger	Partial	Thursday, April 12, 2018
1	Matt Munger 04/12/2018 3:10 PM The correct Kennedy Hydrants were on site as well as epoxy coated fittings. The hydrants were marked 5 1/4 and 250 CWP.		

**Comments:**