

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRSITE20180252, Development - Site

TAILOR MADE LANDING

Address: 1600 SE HAMBLER RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DE-Fire Line Construction Inspection Informational	John DiMauro	Partial	Thursday, April 12, 2018
1	John DiMauro 04/12/2018 3:13 PM		

The crew has installed approximately 300'ft of the 8" C-900 fire line at this time. They poured four of the thrust blocks along the line at the 45 degree bends. There appears to be sufficient rock bedding under the pipe. The thrust block appear to meet the City of Lee's Summit design criteria. The fittings used are approved according to the D&C.

Comments: