

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20172757, Building Permit - Commercial

Address: 300 SW BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Framing Inspection - Commercial</b>	Mark Harding	Partial	Friday, April 13, 2018

### Partial Correction

1	Misc	OK WHEN READY TO INSTALL SHEATHING TO FACADE VERTICAL FACE ABOVE SOFFIT ELEVATION.
---	------	---

OK TO COVER WHEN READY LIGHT GAUGE STEEL FRAMING AT:  
SOFFITS AND VERTICAL FRAMING ABOVE HARBOR FREIGHT  
ENTRANCE; COLUMN WRAP AND BUMP-OUTS AT GRADE;  
["BUMP-OUT" PER DETAIL 1/A310;  
DECORATIVE COLUMN AT SE EXTERIOR CORNER OF BUILDING  
APPROVED

### Corrective Action Required

2	THE FOLLOWING AREAS ARE APPROVED	A204 8-9 SEE PLANS
---	-------------------------------------	--------------------

### Comments: