
PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRSITE20180515, Development - Site

Abundant Life Food Pantry

Address: 1300 SW JEFFERSON ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Sanitary - Material Verification	Matt Munger	Partial	Friday, April 13, 2018

Corrective Action Required

1 Matt Munger 04/13/2018 2:46 PM
Material submittal was received and SDR-35 fittings were submitted and I have informed Ryan Warman (Pearce Construction) that our specs call for SDR-26 fittings. Ryan sent back in an email that they would make sure the fittings were what is required.

DEI-Miscellaneous PWORKS Inspection	Matt Munger	Partial	Friday, April 13, 2018
-------------------------------------	-------------	---------	------------------------

Informational

1 Matt Munger 04/03/2018 3:05 PM
No activity on site.

Informational

2 Matt Munger 04/09/2018 11:38 AM
No activity on site.

Informational

3 Matt Munger 04/13/2018 2:44 PM
Stakes have been put out on site.

Comments:
