Development Services Department

220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20171689, Building Permit - Commercial Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

In-wall Inspection John Borns Partial Monday, April 16, 2018

Partial Correction

1 Misc OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING

+ IN-WALL SYSTEMS AT FOLLOWING SPACES/LOCATIONS: ROWS F THROUGH J, AND 17.3 THROUGH 16; STORAGE RM 1A226; RESTROOM 1A232; STORAGE RM 1A250; RESTROOM 1A217; CLEAN RM 1A218; EXTERIOR WALL AT 1A263 & 1A268; 261; 262.1; 262.2; 267; 218 COMPLETE; 263 COMPLETE; 210 COMPLETE; 258; 260; CORR 259; 209 S WALL; 213-215 E WALL; 266 N WALL; 266 W WALL B/F; 256 N WALL B/F; 1A044 E; 1A200-203; 206-207; 256 S; S WALL AT 1A255 FROM D' TO E' BOTH FACES; A264 S WALL, W WALL, HEADERS/BULKHEADS AT CART WASHER; 1A044 N WALL, S WALL + WALL @ CENTER; 042 S WALL; CART WASH S WALL; NEW/ MODIFIED WALLS @ 1A091 N & W; MODIFIED WALL @ DOOR OPNG 1A044.2; [WALL SECTIONS WITH DOOR OPENINGS AT 1A044 NE + INTERSECTING WALL @

DOOR OPNG 1A055;

Comments: