

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20171395, Building Permit - Commercial

Address: 110 SE 3RD ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Borns	Failed	Monday, April 16, 2018

### Corrective Action Required

1	Misc	RETURN AIR TO BE CLARIFIED WITH LS PLANS EXAMINER. DO NOT PLACE TILE PRIOR TO APPROVAL.
---	------	--

### Corrective Action Required

2	Misc	REMOVE ABANDONED ELECTRICAL BOX AT NE SPACE.
---	------	--

### Corrective Action Required

3	Misc	INSTALL SLACK WIRES ON 2x4 LIGHT FIXTURE AT SE SPACE.
---	------	---

### Comments: