

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20171401, Public Works Infrastructure Permit - Commercial
Ward Rd Expansion
Address: 700 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Erosion Sediment Control (ESC) Inspection	Steve Robbins	Partial	Monday, April 16, 2018

Informational

1 This morning emery sapp is installing silt fence alon ward rd. in the area's where the silt is running down the hill to the sidewalk up past tudor rd. Steve Robbins 04/12/2018 12:43 PM

Informational

2 The silt fence has been installed and is in place. They are also working on getting vegetation established. Steve Robbins 04/16/2018 11:57 AM

Comments: