

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20170757, Building Permit - Residential

Address: 1700 NE PARKWOOD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Tuesday, April 17, 2018

Corrective Action Required

1	Misc	-SHALL INSTALL EROSION CONTROL ALONG THE BACK SIDE OF THE LOT. SEE MUD PILE ON CHAPEL MANOR DR -OBTAIN LAWN IRRIGATION PERMIT AND SUBMIT TO CITY THE BACKFLOW TEST REPORT -FINAL GRADE, SOD, SPLASHBLOCKS -INSTALL RECEPTACLE FOR THE KITCHEN ISLAND -THE WALL RECEPTACLE SPACING AT THE KITCHEN COUNTERTOP IS NOT COMPLIANT
---	------	--

Comments: