

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161771, Building Permit - Commercial

Address: 819 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Tuesday, April 17, 2018

Partial Correction

3

Misc

OK TO COVER WHEN READY 5/8" TYPE X GWB AT CEILINGS & WALLS THROUGHOUT AT:

4TH FLOOR; 3RD FLOOR; 2ND FLOOR; 1ST FLOOR; **[BASEMENT INCLUDING STAIRWELLS, 2ND LAYER AT SHEAR WALLS, BACK FACE OF STAIRWELLS & ELEVATOR SHAFT + 4TH LAYER AT ELEVATOR MACHINE ROOM CEILING ALL OK TO TAPE, MUD AND FIRE-STOP**

GWB AT SHEAR WALLS, BACKSIDE OF STAIRWELL AND ELEVATOR WALLS AT UNITS & CORRIDOR: 4TH FLOOR 1ST LAYER; 3RD FLOOR 1ST LAYER; 2ND FLOOR 1ST LAYER; 1ST FLOOR 1ST LAYER;

-2ND LAYER IN ELEVATOR ROOM; 3RD LAYER + HAT CHANNEL;

-COMPLETE NAIL-OFF FOR -OK

-BASEMENT SHEAR WALLS-OK

Comments: