

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20171395, Building Permit - Commercial

Address: 110 SE 3RD ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Borns	Passed	Tuesday, April 17, 2018

**Comments: TENANT HAS BEEN ADVISED THIS DATE TO SATISFY DISCUSS WITH HVAC CONTRACTOR THE RETURN AIR CONFIGURATION AND ENSURE IT WILL PERFORM ADEQUATELY.**