

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20180434, Building Permit - Commercial

Address: 2751 NE DOUGLAS ST, Unit:X, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	Khanh Nguyen	Partial	Wednesday, April 18, 2018

### Partial Correction

1	Miscellaneous Correction	-UFER GROUNDING CONNECTION (CAD WELD TO REBAR) CONFIRMED -UNDERSLAB ELECTRICAL INSIDE BUILDING-PARTIAL
---	--------------------------	--

### Comments: