

# Temporary Certificate of Occupancy

---

**Permit #:** PRRES20170757  
**Address:** 1700 NE PARKWOOD DR, LEES SUMMIT, MO 64064  
**Inspected On:** Friday, April 20, 2018  
**Inspected By:** Khanh Nguyen  
**Expiration Date:** 5/21/2018 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Khanh Nguyen	Temporary C of O	Friday, April 20, 2018

Corrective Action Required:

1	Misc	-FINAL GRADE, SOD, SPLASHBLOCKS -INSTALL RECEPTACLE FOR THE KITCHEN ISLAND **THE RECEPTACLE AT THE KITCHEN ISLAND SHALL BE GFCI-PROTECTED
---	------	--