

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20173192, Building Permit - Residential

Address: 1687 NE PARKWOOD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Friday, April 20, 2018

Corrective Action Required

1	Misc	-OBTAIN LAWN IRRIGATION PERMIT AND SUBMIT TO CITY THE BACKFLOW TEST REPORT -FINAL GRADE, SOD, SPLASHBLOCKS -SEAL EXTERIOR: PENETRATIONS, ABOVE METER, AC DISCONNECT, ETC -GARAGE DOOR NOT SELF-CLOSING
---	------	---

Comments: