

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20173427, Building Permit - Residential

Address: 1349 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Residential	Khanh Nguyen	Passed	Friday, April 20, 2018

Comments:

THE UFER GROUNDING CONNECTION IS LOCATED IN EXTERIOR WALL OF REAR BEDROOM. THIS GROUNDING CONNECTION IS REQUIRED TO BE ACCESSIBLE. CHECK AT FINAL