

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20173798, Building Permit - Residential

Address: 2562 NE DALE HUNTER LN, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Mechanical Inspection - Residential	Khanh Nguyen	Failed	Friday, April 20, 2018

Corrective Action Required

1	Misc	-INSTALL MAXIMUM 20 AMP BREAKER FOR THE AC UNIT -PROVIDE COMBUSTION AIR OPENINGS PER CODE
---	------	--

Comments: