

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20180728, Building Permit - Residential

Address: 1845 SW BLACKSTONE CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Mike Copeland	Partial	Friday, April 20, 2018

Partial Correction

1 Misc

FOOTING SPREAD 32" FEET WITH 4 #4 BARS CONTINUOUS. READ ENGINEER REPORT ON SITE AND IN ACCORDANCE WITH THE LETTER.

OKAY TO POUR AT OWN RISK PENDING SUBMITTLE OF ENGINEER APPROVAL.

Comments: