

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20173808, Building Permit - Residential
Address: 4716 NE POCONO CIR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Monday, April 23, 2018

Corrective Action Required

1	Miscellaneous Correction	-Cut joist below master toilet **complete the plumbing
---	--------------------------	---

****REINSPECTION FEE ASSESSED. THIS IS THE 6TH TIME THAT I'VE BEEN HERE.**

Electrical Service Inspection - Residential	Khanh Nguyen	Failed	Monday, April 23, 2018
--	--------------	--------	------------------------

Corrective Action Required

1	Miscellaneous Correction	-Install a listed rebar grounding clamp.
---	--------------------------	--

Comments: