

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20170595, Building Permit - Residential

Address: 1341 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Monday, April 23, 2018

Corrective Action Required

1	Misc	-SEAL EXTERIOR LIGHTS
		-INSTALL SPARKRINGS FOR OUTLET BOXES AT FIREPLACE RECESSED MORE THAN 1/4" BEHIND NON-COMBUSTIBLE WALL SURFACE

Comments: