

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20180476, Building Permit - Residential

Address: 1345 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sewer Service Inspection - Residential	Khanh Nguyen	Partial	Tuesday, April 24, 2018

Partial Correction

1	Misc	-PARTIAL FROM THE SEWER CONNECTION TO THE STUB BELOW STREET CURB TO ~40 FT TOWARD HOUSE. OK TO BACKFILL THIS SECTION
---	------	--

Water Service Inspection - Residential	Khanh Nguyen	Not Ready	Tuesday, April 24, 2018
---	--------------	-----------	-------------------------

Comments:

TRACER WIRE WAS NOT INSTALLED WITH THE SEWER STUB. THE CONTRACTOR JUST INSTALLED THE TRACER WIRE FROM THE STUB CONNECTION AND RUN IT TO THE HOUSE.