

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20173605, Public Works Infrastructure Permit - Commercial
Village at View High - Off-Site Sanitary Sewer
Address: 325 NW VIEW HIGH DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Sanitary Sewer - Air Test	Steve Robbins	Passed	Wednesday, April 25, 2018

Informational

1 We did the air test from existing Mh to A-o , A-o to A-1, and A-1 to A-2. The testing passed up to MH A-2. They are going to do the rest on april 23.Steve Robbins 03/30/2018 9:04 AM

Informational

2 Today we did the air test on MH A2-A-7. After today everything passed up to A-7.Steve Robbins 04/20/2018 3:52 PM

Corrective Action Required

3 Today we did the air test from a-6 to a-10. Everything passed.Steve Robbins 04/24/2018 8:30 AM

Informational

4 The air testing from A-10 to A-15 has been completed. This completes the testing from A-0 to A-15. Everything has passed for the air test.Steve Robbins 04/25/2018 1:27 PM

Comments: