

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRRES20171753, Building Permit - Residential

Address: 1824 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mark Harding	Failed	Thursday, April 26, 2018

### Corrective Action Required

1	Misc	<ul style="list-style-type: none"><li>- LAWN SPRINKLER PERMIT</li><li>- INCORRECT PIPING AT WATER HEATER DISCHARGE</li><li>-NO BSMT HANDRAIL, NEEDS TO EXTEND TO LAST STEP.</li><li>-OPEN LIGHTS IN MSTR CLOSET.</li><li>-OPEN WIRING UNDER FRONT PORCH.</li><li>-NO EGRESS LADDER</li><li>-LABEL SMOKES AT PANEL.</li><li>- SEAL BSMT AT I BEAM FROM GARAGE AT TOP OF FOUNDATION WITH FIRE CAULK.</li></ul>
---	------	--

### Comments: