

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRSUBD20180158, Development - Subdivision

Park Ridge 6th Plat

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Erosion Sediment Control (ESC) Inspection Informational	Jeremy Young	Partial	Thursday, April 26, 2018
1	Jeremy Young 04/09/2018 9:28 AM All ESC devices are intact and seem to be functioning properly. I have asked the crew to add gutter protection to the 2 inlets on Bluestone.		
2	Jeremy Young 04/19/2018 3:38 PM All ESC devices appear to be intact and working properly. All silt fences and mulch is intact.		
3	Jeremy Young 04/26/2018 3:41 PM Please add some mulch to the east side of the road on Bluestone. There was some utility work done and the ESC needs to be put back.		

Comments: