

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRRES20173060, Building Permit - Residential

Address: 1705 NE PARKWOOD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Jeremy Young	Partial	Monday, April 30, 2018

Informational

- 1 Jeremy Young 04/30/2018 7:11 AM Contractor has at least 4" of compacted aggregate base. I have advised them to stay under 2.0% cross slope where the sidewalk will pass through the driveway. They will add expansion joints.

DEI-Sidewalk Inspection	Jeremy Young	Partial	Monday, April 30, 2018
-------------------------	--------------	---------	---------------------------

Informational

- 1 Jeremy Young 04/30/2018 7:08 AM Contractor has at least 4" of compacted aggregate base. They have under 1.5% cross slope which meets ADA standards. They will add expansion joints.

Comments: