

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20174063, Public Works Infrastructure Permit - Commercial
COLEMAN EQUIPMENT - WATER MAIN EXTENSION
Address: 4101 NE LAKEWOOD WAY, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Water - Material Verification Informational	Jeremy Young	Partial	Monday, April 30, 2018

- 1 Jeremy Young 04/30/2018 11:43 AM Contractor had the materials delivered. The pipe is C900, and manufactured within the last year. The fire hydrants are Waterous 250 with the WB67B label. The valves are AWWA C515 D16. The tracer wire is 12mil and the restrained joint pipe is CertaLok.

Comments: