

# Temporary Certificate of Occupancy

---

**Permit #:** PRCOM20180458  
**Address:** 3680 NE AKIN DR, Unit:114, LEES SUMMIT, MO 64064  
**Inspected On:** Tuesday, May 01, 2018  
**Inspected By:** Khanh Nguyen Michael Weissenbach  
**Expiration Date:** 6/1/2018 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Khanh Nguyen	Temporary C of O	Tuesday, May 01, 2018

**Corrective Action Required:**

1	Misc	-INSTALL ACCESSIBILITY-COMPLIANT DOOR HARDWARE FOR RESTROOM -ALL RECEPTACLES WITHIN SIX FT OF THE MOP SINK MUST BE GFCI-PROTECTED -GAS TEST NOT PERFORMED
---	------	---

<b>Alarm Test</b>	Michael Weissenbach	Passed	Tuesday, May 01, 2018
-------------------	------------------------	--------	--------------------------

<b>Occupancy Inspection - Fire</b>	Michael Weissenbach	Passed	Tuesday, May 01, 2018
--	------------------------	--------	--------------------------

