

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20170784, Building Permit - Commercial

Address: 3621 NE AKIN DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

|   |              |          |                       |
|---|--------------|----------|-----------------------|
| Inspection:                               | Inspector:   | Outcome: | Date:                 |
| <b>Gas Piping Inspection - Commercial</b> | Khanh Nguyen | Partial  | Tuesday, May 01, 2018 |

Partial Correction

1 Misc

PARTIAL: INSPECT GAS LINE FROM CONNECTION TO VALVE AT MAIN PIPE TO GENERATOR. STILL NEED TO PRESSURE-TEST

**Comments:**