

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161942, Building Permit - Commercial

Address: 819 NW DONOVAN RD, Unit:G1, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Partial	Wednesday, May 02, 2018

Partial Correction

1 Misc

OK TO COVER CEILINGS WHEN READY.

BOTTOM PLATES MARKED WHERE ANCHOR BOLTS ARE TO BE ADDED AND RE-INSPECTED WHEN READY.

Comments: