

**PUBLIC WORKS ENGINEERING DIVISION**

## Inspection Summary

Permit #: PRRES20173060, Building Permit - Residential

Address: 1705 NE PARKWOOD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

**Inspection Item:**

<b>Inspection:</b>	<b>Inspector:</b>	<b>Outcome:</b>	<b>Date:</b>
DEI-Sidewalk Inspection	Jeremy Young	Passed	Thursday, May 03, 2018

Informational

- 1 Jeremy Young 04/30/2018 7:08 AM Contractor has at least 4" of compacted aggregate base. They have under 1.5% cross slope which meets ADA standards. They will add expansion joints.

Informational

- 2 Jeremy Young 05/03/2018 1:07 PM Contractor has poured the sidewalk. They have sufficient compacted rock base. The sidewalk has between .02-1.8% cross slope which meets ADA standards.

Driveway Inspection	Jeremy Young	Passed	Thursday, May 03, 2018
---------------------	--------------	--------	---------------------------

Informational

- 1 Jeremy Young 05/03/2018 1:09 PM Contractor has poured the driveway approach. They have added the expansion joints and the approach is at least 6" thick. They have between 1.0-1.6% cross slope which meets ADA standards.

**Comments:**