

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20172757, Building Permit - Commercial

Address: 300 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Failed	Friday, May 04, 2018
Partial Correction			
1 Misc		OK WHEN READY TO INSTALL SHEATHING TO FACADE VERTICAL FACE ABOVE SOFFIT ELEVATION.	
		OK TO COVER WHEN READY LIGHT GAUGE STEEL FRAMING AT: SOFFITS AND VERTICAL FRAMING ABOVE HARBOR FREIGHT ENTRANCE; COLUMN WRAP AND BUMP-OUTS AT GRADE; ["BUMP-OUT" PER DETAIL 1/A310; DECORATIVE COLUMN AT SE EXTERIOR CORNER OF BUILDING APPROVED	
Partial Correction			
2 THE FOLLOWING AREAS ARE APPROVED		A204 8-9 SEE PLANS; AREA DUE WEST OF PLANET FITNESS TO CORNER.	
Corrective Action Required			
3 Misc		HANGING FACIA AT SW CORNER OF PLANTER FITNESS: SCREW ALL FLANGES OF TENSION STUDS AT TOP & BOTTOM TRACKS;	

Comments: