

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRRES20180146, Building Permit - Residential

Address: 4721 NE POCONO CIR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:

Inspector:

Outcome:

Date:

**All Rough Inspection -  
Residential**

Khanh Nguyen

Failed

Friday, May 04, 2018

Corrective Action Required

1 Misc

FRAMING:

-Fb basement wall from soffit

MECHANICAL:

-Lower duct to basement bath ceiling level

**\*\*OK TO INSULATE**

**Comments:**